This whole report is not valid if the serial number on any page of the report has been defaced or altered

AVEnnn-XXnnX_nn SCID1

SCHEDULE OF CIRCUITS AND DISTRIBUTION

Issued in accordance with British Standard 7671 – Requirements for Electrical Wiring

A DISTRIBUTION BOARD DETAILS

Designation		Location	

B DISTRIBUTION BOARD not connected directly to the origin

Supply to distribution board			Overcurrent protective device			RCD (if applicable)		
From designation	N/A		No of phases	N/A		Type BS (EN)	N/A	
No of poles	N/A		Type BS (EN)	N/A		No of poles	N/A	
Nominal voltage, U / U_o	N/A	V	Device rating	N/A	A	Current rating, $I_{\Delta n}$	N/A	A

C SCHEDULE OF CIRCUIT DETAILS

Circuit number and phase	Circuit designation	Type of wiring († see table below)	Reference method	Number of points served	Circuit conductors, csa		Max permitted disconnection time	Overcurrent protective devices				RCD	Maximum permitted Z_s
					Live	cpc		BS (EN)	Type Number	Rating	Short-circuit capacity	Operating current	
					mm^2	mm^2	s			A	kA	mA	Ω

COPYRIGHT MJG 2007

† CODES FOR TYPE OF WIRING

A	B	C	D	E	F	G	H	O (Other)
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XPLE/SWA cables	Mineral-insulated cables	

© Copyright MJG 2007

This safety report is an important and valuable document. It should be retained for future reference